

Certificate Number: AZ 69025489

Page: 0001



CERTIFICATE OF SUITABILITY

Authorised marking: TUV025489E

This is to certify that TÜV Rheinland Australia Pty Ltd as accredited by JAS-ANZ in accordance with ISO/IEC 17065 has examined for compliance with certification standards, the electrical equipment described hereunder and authorises the certificate holder to affix the above mentioned mark to products of the same type; or the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled

CERTIFICATE HOLDER:

Fronius Australia Pty. Ltd.
90-92 Lambeck Drive
Tullamarine VIC 3043
Australia

DESCRIPTION OF EQUIPMENT

Declared class:

Non-declared

Product:

Solar Grid Tied Inverter

Trade Name / Manufacturer:

FRONIUS

Model Number:

Fronius Symo 3.0-3-M; Fronius Symo 3.7-3-M;
Fronius Symo 4.5-3-M; Fronius Symo 5.0-3-M;
Fronius Symo 5.5-3-M; Fronius Symo 6.0-3-M;
Fronius Symo 6.7-3-M; Fronius Symo 7.0-3-M;
Fronius Symo 8.0-3-M; Fronius Symo 8.2-3-M

Ratings:

Ratings refer to CONTINUATION SHEET 1-4 for details
Remarks: Alternative Authorised marking 'TUV021501E'
is applicable to above mentioned models

Standard:

IEC 62109-1:2010
IEC 62109-2:2011
AS/NZS 4777.2:2020+A1

Issue Date:

17/11/2021

Expiry Date:

17/11/2026

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read 'Grant Li'.

Grant Li



Acc. No. Z2870404AA
www.jas-anz.org/register

Certificate Number: AZ 69025489

Page: 0002



CERTIFICATE OF SUITABILITY

Authorised marking: TUV025489E

CONTINUATION SHEET 1

DESCRIPTION OF EQUIPMENT

Ratings:

For all models:

Operating Temp.: -25°C to 60°C,

Overvoltage Category (OVC): PV input: II; Grid Output: III

Protection: Class I, IP65, PD 2 (inside); PD 3 (outside)

For models Fronius Symo 3.0-3-M ; Fronius Symo 3.7-3-M ;

Fronius Symo 4.5-3-M

Input:

VDC max: 1000Vd.c.,

VDC MPPT: 150-800Vd.c.,

Isc PV: 2 x 24.0A

IDC max: 2 x 16.0A

Output:

Nominal grid voltage: 3~NPE 220/230V / 380/400V

Nominal frequency: 50/60Hz

Power factor cos phi: 0.85 – 1 ind/cap

Rated Output Power: 3000W; 3700W; 4500W

Max / Rated apparent power: 3000VA; 3700VA; 4500VA

Rated current at 220/230V: 4.6A/4.4A; 5.6A/5.4A; 6.8A/6.5A

Max output current: 13.5A

Issue Date: 17/11/2021

Expiry Date: 17/11/2026

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd



Grant Li



Acc. No. Z2870404AA
www.jas-anz.org/register

Certificate Number: AZ 69025489

Page: 0003



CERTIFICATE OF SUITABILITY

Authorised marking: TUV025489E

CONTINUATION SHEET 2

DESCRIPTION OF EQUIPMENT

Ratings:

For models Fronius Symo 5.0-3-M ; Fronius Symo 5.5-3-M ;
Fronius Symo 6.0-3-M

Input:

VDC max: 1000Vd.c.,
VDC MPPT: 163-800; 179-800; 195-800Vd.c.,
Isc PV: 2 x 24.0A
IDC max: 2 x 16.0A

Output:

Nominal grid voltage: 3~NPE 220/230V / 380/400V
Nominal frequency: 50/60Hz
Power factor cos phi: 0.85 – 1 ind/cap
Rated Output Power: 5000W; 5500W; 6000W
Max / Rated apparent power: 5000VA; 5500VA; 6000VA
Rated current at 220/230V: 7.6A/7.3A; 8.3A/8.0A; 9.1A/8.7A
Max output current: 13.5A

Issue Date: 17/11/2021

Expiry Date: 17/11/2026

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read 'Grant Li', positioned above a horizontal line.

Grant Li



Acc. No. Z2870404AA
www.jas-anz.org/register

Certificate Number: AZ 69025489

Page: 0004



CERTIFICATE OF SUITABILITY

Authorised marking: TUV025489E

CONTINUATION SHEET 3

DESCRIPTION OF EQUIPMENT

Ratings:

For models Fronius Symo 6.7-3-M ; Fronius Symo 7.0-3-M ;
Fronius Symo 8.0-3-M ;

Input:

VDC max: 1000Vd.c.,
VDC MPPT: 218-800; 228-800; 260-800Vd.c.,
Isc PV: 2 x 24.0A
IDC max: 2 x 16.0A

Output:

Nominal grid voltage: 3~NPE 220/230V / 380/400V
Nominal frequency: 50/60Hz
Power factor cos phi: 0.85 – 1 ind/cap
Rated Output Power: 6700W; 7000W; 8000W
Max / Rated apparent power: 6700VA; 7000VA; 8000VA
Rated current at 220/230V:
10.2A/9.7A; 10.6A/10.2A; 12.1A/11.6A;
Max output current: 13.5A

Issue Date: 17/11/2021

Expiry Date: 17/11/2026

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read 'Grant Li', positioned above a horizontal line.

Grant Li



Acc. No. Z2870404AA
www.jas-anz.org/register

Certificate Number: AZ 69025489

Page: 0005



CERTIFICATE OF SUITABILITY

Authorised marking: TUV025489E

CONTINUATION SHEET 4

DESCRIPTION OF EQUIPMENT

Ratings:

For models Fronius Symo 8.2-3-M ;

Input:

VDC max: 1000Vd.c.,

VDC MPPT: 267-800Vd.c.,

Isc PV: 2 x 24.0A

IDC max: 2 x 16.0A

Output:

Nominal grid voltage: 3~NPE 220/230V / 380/400V

Nominal frequency: 50/60Hz

Power factor cos phi: 0.85 – 1 ind/cap

Rated Output Power: 8200W

Max / Rated apparent power: 8200VA

Rated current at 220/230V: 12.4A/11.9A

Max output current: 13.5A

Issue Date: 17/11/2021

Expiry Date: 17/11/2026

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

A handwritten signature in blue ink, appearing to read "Grant Li".

Grant Li



Acc. No. Z2870404AA
www.jas-anz.org/register